

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## LICENCE FOR HAR CONFORMITY MARK

No.: 6170015

**Licensee:** nkt cables automotive s.r.o.  
Českých bratří 509, 543 01 Vrchlabí, Czech Republic

**Factory:** nkt cables automotive s.r.o.  
Českých bratří 509, 543 01 Vrchlabí, Czech Republic

**Type of product:** Flexible cables with thermoplastic PVC insulation

**Code of product:** H03VVH2-F

**Rating:** 2 x (0,5 - 0,75) mm<sup>2</sup>; 300/300 V

**Trade Mark:**

Electrotechnical Testing Institute is granting a licence for using the following mark



or identification thread (black – 1 cm, red – 3 cm, yellow – 11 cm), (code 22).

One of these marks may be used for the product specified in this certificate within validity of the Agreement on the use of the HAR Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No.: 300324-01/01 of 29.1.2013

A sample of the product was tested and found to be in conformity with:  
EN 50525-2-11:2011  
ČSN EN 50525-2-11:2011

- certified quality system according to of performed by EZÚ
- the General Agreement on the use of the HAR Mark No. 1810 and the agreement No. 605673-15 concluded between the ordering firm and the Electrotechnical Testing Institute
- compliance with the certification scheme „HAR“

Certificate supersedes: -

This certificate is issued according to the rules of the HAR Agreement. The certification Scheme meets the criteria for type 5 systems laid down in the ISO/IEC Guide 67:2004 (Type Testing, Factory Inspection with assurance of conformity by continuous sample testing, production surveillance and market surveillance). The certificate issued by any Certification Body adhering to the HAR Agreement has the same worth and validity in all the other Certification Bodies' countries.

Compliance with the requirements of the above listed Harmonised Standards carries a presumption of conformity with the essential safety requirements of Directive 2006/95/EC (Low Voltage Directive).

17.01.2017

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



605673-15