

DELTA PLUS GROUP declares that this product complies with the following regulations :

Identification of the PPE object of the declaration :

**VV914KV10 - VV914 ARC FLASH**

Designation :

ELECTRIC ARC RESISTANT GLOVE

Colour :

Yellow-Black

Size :

10



Specifications :

Para-aramid/Fibreglass/Modacrylic. Foam neopren coating on palm and fingertips. Gauge 10.

The PPE is also identifiable by the following means :

- The product picture
- Each PPE wears the name indicated on this declaration of conformity.
- Each PPE wears the bar code indicated in the annex to this declaration of conformity
- Each PPE wears a batch number. For any further information, just give it to us. Our organization, based on this batch number, allows us to ensure the traceability of the PPE.

#### EU DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The object of the declaration identified above is in conformity with the relevant Union harmonisation legislation:

EU 2016/425 Regulation, with its requirements and with the harmonised standards:



REGULATION (EU) 2016/425

EN ISO 21420:2020 General requirements

EN388:2016+A1:2018 Protective gloves against mechanical Risks (Levels obtained on the palm)



- 3: Resistance to abrasion (from 1 to 4)
- X: Resistance to cutting (from 1 to 5)
- 4: Resistance to tear (from 1 to 4)
- 3: Resistance to puncture (1 to 4)
- E: Resistance to cutting by sharp objects (TDM EN ISO 13997) (from A to F)

EN407: 2020 Protective gloves against Heat & Fire risks (X = Unrealized test)



- 4: Flame spread resistance.
- 2: Contact heat resistance (from 1 to 4)
- X: Convective heat resistance (1 to 4)
- X: Radiant heat resistance (from 1 to 4)
- X: Small splashes of molten metal (from 1 to 4)
- X: Large quantities of molten metal (from 1 to 4)

## DECLARATION OF CONFORMITY

0075 - C.T.C. (PARC TONY GARNIER 4 RUE HERMANN FRENKEL 69367 LYON CEDEX 07 FRANCE) :  
Notified body which performed the EU Type- examination (module B) and issued EU type-examination  
certificate: 0075 022 162 05 21 0914

## USA STANDARDS



ASTM-F-2675M:2013 Standard Test Method for Determining Arc Ratings of Hand Protective Products Developed and Used for Electrical Arc Flash Protection.

50 (CAL/CM<sup>2</sup>): Arc Thermal Performance Value (cal/cm<sup>2</sup>).

Apt, 24/11/2022

Signed for and on behalf of DELTA PLUS GROUP :  
David GUIHO  
Marketing director

**DELTA PLUS GROUP**  
SA au capital de 2 676 700 €  
RCS 140  
54405 APT CEDEX - France  
Tél : 04 90 74 20 33 - fax : 04 90 74 32 59  
Site : 334 631 866 (www)  
TVA intracommunautaire : FR 20 334 631 866

ANNEX:

| Item details |               |              |      |
|--------------|---------------|--------------|------|
| Item details | Bar code      | COLOUR       | SIZE |
| VV914KV10    | 3295249264260 | Yellow-Black | 10   |