SIEMENS

Data sheet

5SL6002-7



CIRCUIT BREAKER 230V 6KA, 1+N-POLE/1MW C2

| Model | | | |
|----------------------------------------------------------------------------------------|--------------------------------------|--|--|
| product brand name | SENTRON | | |
| product designation | Miniature circuit breaker | | |
| design of the product | Miniature circuit breaker compact | | |
| General technical data | | | |
| design of pole | 1P+N | | |
| tripping characteristic class | C | | |
| mechanical service life (operating cycles) typical | 4 000 | | |
| overvoltage category | Ш | | |
| degree of pollution | 2 | | |
| Voltage | | | |
| type of voltage of the operating voltage | AC | | |
| insulation voltage (Ui) at AC rated value | 250 V | | |
| Supply voltage | | | |
| supply voltage | | | |
| at AC rated value | 230 V | | |
| at DC rated value | 60 V | | |
| value range of the supply voltage frequency | 50/60 Hz | | |
| operating voltage | | | |
| • minimum | 24 V | | |
| with single-phase operation at AC maximum | 250 V | | |
| Protection class | | | |
| protection class IP | IP20, with connected conductors | | |
| Switching capacity | | | |
| switching capacity current | | | |
| according to EN 60898 rated value | 6 kA | | |
| energy limitation class | 3 | | |
| Dissipation | | | |
| power loss [W] for rated value of the current at AC in hot operating state per pole | 1.3 W | | |
| Suitability | | | |
| suitability for operation | Residential buildings/infrastructure | | |
| Product details | | | |
| product component | | | |
| combined terminal top | No | | |
| combined terminal bottom | No | | |
| neutral conductor switching | Yes | | |
| product feature | | | |
| properties for main switches in accordance with EN 60204-1 | No | | |

| halogen-free | Yes | | | |
|---------------------------------------------------------------------------------|----------------------------|----------------|----------------------------------|--|
| - | | | | |
| • sealable | | Yes | | |
| • silicon-free | | Yes | | |
| product extension installable supplementary devices | Yes | | | |
| Connections | | | | |
| connectable conductor cross-section solid | | | | |
| • minimum | 0.75 mm² | | | |
| • maximum | 16 mm² | | | |
| connectable conductor cross-section stranded | | | | |
| • minimum | | 0.75 mm² | | |
| • maximum | 16 mm² | | | |
| connectable conductor cross-section finely stranded with core end processing | | | | |
| • minimum | 0.75 mm² | | | |
| • maximum | 10 mm² | | | |
| tightening torque [lbf·in] with screw-type terminals | | | | |
| • minimum | 17.7 lbf·in | | | |
| • maximum | 22.1 lbf·in | | | |
| tightening torque with screw-type terminals | | | | |
| • minimum | 2 N·m | | | |
| • maximum | 2.5 N·m | | | |
| position of power supply cord | Any | Any | | |
| Mechanical Design | | | | |
| height | 90 mm | | | |
| width | 18 mm | | | |
| depth | 76 mm | | | |
| installation depth | 70 mm | | | |
| number of modular width units | 1 | | | |
| fastening method | DIN rail | | | |
| mounting position | any | | | |
| net weight | 113.2 g | • | | |
| Environmental conditions | | | | |
| standard | IEC/EN60898-1, GB/T10963.1 | | | |
| vibration resistance according to IEC 60068-2-6 | Yes | | | |
| ambient temperature during operation | 103 | | | |
| minimum | -25 °C | | | |
| | | -25 C 60 °C | | |
| maximum | 80°C | | | |
| ambient temperature during storage | 40 °C | | | |
| • minimum | -40 °C | | | |
| maximum | 75 °C | | | |
| number of test cycles for environmental testing according to IE 60068-2-30 | C 6 | | | |
| Approvals Certificates | | | | |
| | | | | |
| General Product Approval | | | | |
| | Confirmation | ~ | ^ | |
| | | | AVE | |
| | シ | | ÷ | |
| EG-Konf. CCC | : | IMQ | VDE | |
| | | | | |
| | | | | |
| General Product Approval Marine / Si | ipping other | | Environment | |
| | | 0- 5 - 7 | Ender 110 | |
| | Miscellaneous | Confirmation | Environmental Con- firmations | |
| | 7 | | | |
| KEMA DN | , | | | |
| | | | | |
| | | | | |
| Further information | | | | |

Further information

Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SL6002-7

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SL6002-7


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SL6002-7


CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications





last modified:

9/21/2023 🖸