thePrema P360 KNX UP GR

Item no.: 2079001

Presence and motion detectors
Ceiling installation indoor

Description

- Passive infra-red presence detector KNX for flush-mounted ceiling installation
- Square detection area 360°, 9 x 9 m, (81 m²) at mounting height 3 m
- 3 channels light and 2 channels presence
- 2 channel light C1, C2 with 2 light measurements and additional lighting channel C3 without brightness factor
- 2 presence channels can be set individually
- Adaptable 3 channel light measurement
- Mixed light measurement suitable for LEDs, fluorescent lamps (FL/PL/ESL) and halogen/incandescent lamps
- Can be used as fully or semi-automatic, switchable
- Switch or constant light control mode with stand-by function
- Dimmable lighting in switch mode with stand-by function
- Brightness switching value or set point value can be set in lux using parameters, on the device itself or via remote control
- Teaching in of the brightness switching value or the set point value
- Room correction factor setting for brightness measurement calibration
- Light time delay can be set using parameters, on the device itself or via remote control
- Switch on delay and time delay for presence can be set
- Detection sensitivity can be set
- Self-learning time delay
- Reduced time delay in the event of a shorter stay in the room (short presence)
- Scenario functions
- Extremely easy setting of energy saving characteristics with the new "eco plus" function
- Test mode for checking function and detection range
- Parallel switching of several detectors in Master/Slave or Master/Master possible
- User remote control and management-remote control (optional)
- Room monitoring
- * According to warranty terms and conditions, see www.theben.de/en/guarantee

Subject to technical changes and misprints

additional information at: www.theben.de/product/2079001

The load data are determined with exemplary selected illuminants and are therefore typical data due to the large number of available products.

30/09/2025

Page 1 of 4

thePrema P360 KNX UP GR
Item no.: 2079001

theben

Technical data

	thePrema P360 KNX UP GR
Installation height	2 - 10 m
Minimum height	1.7 m
Measuring range brightness	5 - 3000 lx
Detection angle	360°
Type of connection	Spring terminals WAGO 243
Installation type	Ceiling installation
Light switch-off delay	30 s - 60 min
Lamp types	Energy saving lamps, fluorescent lamps, Incandescent/halogen lamps, LEDs

	thePrema P360 KNX UP GR
Light measurement	Mixed light measurement
Presence switch-off delay	10 s - 120 min
Switch-on delay presence	10 s - 30 min / inactive
Ambient temperature	0°C ... 50°C
Detection range	81 m² (9,0 x 9,0 m)
Colour	Grey
Type of protection	IP 40 (when fitted)

Detection range for planning applications at a temperature of 21 °C

Mounting height (A)	Sitting (S)	Walking (T)
2 m	20 m² | 4.5 m x 4.5 m	36 m² | 6 m x 6 m ± 0.5 m
2.5 m	36 m² | 6 m x 6 m	64 m² | 8 m x 8 m ± 0.5 m
3 m	49 m² | 7 m x 7 m	81 m² | 9 m x 9 m ± 1 m
3.5 m	64 m² | 8 m x 8 m	100 m² | 10 m x 10 m ± 1 m
5 m		144 m² | 12 m x 12 m ± 1.5 m
10 m		400 m² | 20 m x 20 m ± 2 m

Detection range according to Sensnorm IEC 63180

Mounting height (A)	Diagonally (T)	Head on to (R)	Sitting (S)
2.5 m	77 m² | 8.8 m x 8.8 m	64 m² | 8 m x 8 m	42 µm | 6.5 m x 6.5 m

thePrema P360 KNX UP GR

Item no.: 2079001

Scale drawings

Accessories

theSenda P
Item no.: 9070910

theSenda S
Item no.: 9070911

Surface frame 110A GR
Item no.: 9070913


Surface frame 110B GR
Item no.: 9070919

Ceiling installation box 73A
Item no.: 9070917

QuickSafe
Item no.: 9070531

theSenda B
Item no.: 9070985

Ceiling installation box 68A
Item no.: 9070992

Subject to technical changes and misprints

additional information at: www.theben.de/product/2079001

The load data are determined with exemplary selected illuminants and are therefore typical data due to the large
number of available products.

30/09/2025
Page 3 of 4

Accessories

Set basic KNX AP Multi WH
Item no.: 9070900

Subject to technical changes and misprints

additional information at: www.theben.de/product/2079001

The load data are determined with exemplary selected illuminants and are therefore typical data due to the large
number of available products.

30/09/2025

Page 4 of 4