

EU DECLARATION OF CONFORMITY

No. 1A-EU-55/26-07

In accordance with EU directive 2014/35/EU as amended

We, KOPOS KOLÍN a. s.
Havlíčková 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

product: **Electrical installation boxes KKD**
type: **KKD 90, KKD 115, KKD 135, KKD 160, KKD 200, KKD 250**
manufacturer: **KOPOS KOLÍN a.s. Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: This electrical junction box, designed for circuits with voltages up to 1000V, is made of insulating material and has protection class II.
Boxes intended for installation in environments that require IP66 protection.
Protection against mechanical impacts: IK07
Clow wire test satisfies: 850°C, orange color 650°C.
Temperature resistance boxes during installation is from -25 °C

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:2021+A11:2021 ČSN EN 60670-22:2007+A1:2025+A11:2025	Test Report No. 261192-01/01 of 29.05.2026 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Test IP 66
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:2021+A11:2021 ČSN EN 60670-22:2007+A1:2025+A11:2025	Test Report No. 252865-01/01 of 30.03.2026 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:2021+A11:2021 ČSN EN 62262+A1:2022	Test Report No. MP-PR-26-149 of 25.06.2026 Issued by: TREVOS, a.s., Nová Ves 34, 511 01 Trutnov, Czech Republic	Test IK07
Regulation 1907/2006 - REACH				Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogue>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.



Place of issue: Kolín, Czech Republic

Date of issue: 01.07.2026

Ing. Jana Dejmková
quality and ecology director

KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-48/26-07
Electrical installation boxes KKD

Type:

KKD 90
KKD 115
KKD 135
KKD 160
KKD 200
KKD 250

Note: applies to all color variants except orange

Electrical installation boxes KKDxxPO- sets of boxes
Variants: Orange

Item	Configuration	number of terminals
KKD 90	PO6-1F	3
KKD 90	PO6	5
KKD 115	PO10-1F	3
KKD 115	DPO8	8
KKD 115	PO6	5
KKD 135	PO16-1F	3
KKD 135	2PO6	5
KKD 135	PO10	5
KKD 160	2PO6-7	7
KKD 160	2PO10	5
KKD 160	PO16	5
KKD 200	DPO16	16
KKD 200	2PO16	5
KKD 200	2PO10-7	7
KKD 200	DPO32	32

Accessories:

PPK 16E
PPK 20
PPK 25
PPK 32
PPK 40
PMK 1
PNP KKD 90
PNP KKD 115
PNP KKD 135
PNP KKD 160
PNP KKD 200
PNP KKD 250

Note: applies to all color variants except orange



KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

